ಬೆಸ್ಕಂ

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

Ref.No.: BESCOM/GM(P)/DGM(P)/AGM(P3)/BC-10/2024-25/3398

Telephone :080-22354939
E-mail: gmproc@bescom.co.in
gmproc.work@gmail.com

O/o The General Manager (Ele),
Procurement Section,
4th Floor, Corporate Office,
BESCOM, K.R. Circle,
Bengaluru–560001.

Date: 03 SEP 2024

AMENDMENT

Sub: Design, Manufacturing and Supply of 25kVA Star-1 (4-Star) Rated 11kV/433V, 3Phase, 50Cycle, Aluminium Wound, CRGO Core Distribution Transformers as per Tender Specification, GTP and Drawing to BESCOM (Lot-1)– Reg.

Ref: BESCOM/2024-25/IND0080

*****

Tender was invited for Procurement of Design, Manufacturing and Supply of 25kVA Star-1 (4-Star) Rated 11kV/433V, 3Phase, 50Cycle, Aluminium Wound, CRGO Core Distribution Transformers as per Tender Specification, GTP and Drawing to BESCOM (Lot-1).

In this regard, some of the prospective Bidders have requested for amendment to the QRs and specifications. The same was placed before the management and was decided as follows:

Sl. No	Clause No	As Existing	Amendment as requested by the Prospective Bidders	Amendment issued
1	Technical Specification clause Sl.no 20	The transformer tank shall be of robust construction only in rectangular /Octagonal shape and shall be built up of electrically tested welded mild steel top and bottom plates thickness of 5.00 mm and 3.15 mm for the side wall thickness.	As per standards for 25 kVA top & bottom sheet thickness will be 3.00 mm only	The transformer tank shall be of robust construction only in rectangular/ Octagonal shape and shall be built up of electrically tested welded mild steel top and bottom plates thickness of 5.00 mm and 3.15 mm for the side wall thickness.

Sl. No	Clause No	As Existing	Amendment as requested by the Prospective Bidders	Amendment issued
				Note: The top and bottom plate thickness may be 3.15mm if HT & LT bushings are provided on the side wall of the tank for 25KVA transformers only.
2	Sl.No 41 Special Test		Report shall be furnished at the time of inspection	Qualifying Requirement No. 6 prevails.
3	QR 11	The Liquid Assets as on last date of previous month of tender or at a later date before submission of the bid consisting of Cash at Bank + Term Deposits + availability of fund based credit facility in any Nationalized/scheduled Bank shall not be lesser than 25% of the amount put to tender.	Kindly confirm from which date to which date - liquid assets	Qualifying Requirement No. 11 prevails.
4	QR 04		In QR no 04 manufactured and supplied for micro and small enterprises kindly consider any ESCOMS to any other state electric utility government organizations to total partial turnkey works	Qualifying Requirement No. 04 prevails.
5			Kindly consider for EMD is nil for micro and small enterprises registered with NSIC under single point vender registration scheme and provide EMD declaration for the same	For MSME registered companies with NSIC, EMD is exempted.

Sl. No	Clause No	As Existing	Amendment as requested by the Prospective Bidders	Amendment issued
6	QR 11		We are herewith requesting you reduce the liquid asset to 12.5 percentage of amount put to tender for micro and small enterprises	Qualifying Requirement No. 11 prevails.

Approved by Managing Director, BESCOM

(Er.Shivaprakash.T.M)
General Manager (Elec.),
Procurement, BESCOM.